

WATER WELL REPORT
STATE OF OREGON

#2

Per WWC: #9 - well sealed from land surface to 120'. # of sacks of cement used in well seal 125 sacks

RECEIVED

DEC 23 1983

State Well No. 65/10W-30

WATER RESOURCES DEPT.
SALEM, OREGON

State Permit No.

LINE 57

(1) OWNER:

Name PIXIE LAND RV PARK
Address Rt. 2 Box 224
City Otis State OR. 97368

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
Cased Bored Thermal: Withdrawal Reinjection

(4) PROPOSED USE (check):

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
6" Diam. from 71 ft. to 39 ft. Gauge 250
" Diam. from " ft. to " ft. Gauge "

LINER INSTALLED:

4" Diam. from 0 ft. to 120 ft. Gauge 173

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills Knife
Size of perforations 1/4 in. by 2 1/2 in.
PVC 88 perforations from 19 ft. to 39 ft.
80 perforations from 40 ft. to 120 ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
" gal./min. with " ft. drawdown after " hrs.
" " " " " " "
Air test 15 gal./min. with drill stem at 119 ft. 1 hrs.
Bailer test gal./min. with " ft. drawdown after " hrs.
Artesian flow g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No
Well seal—Material used CEMENT GROUT
Well sealed from land surface to _____ ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal _____ sacks
How was cement grout placed? PRESSURE GROUTED

Was pump installed? yes Type Sub. HP _____ Depth _____ ft.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of Water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from 0 ft. to 120 ft. around filter

(10) LOCATION OF WELL:

County LINCOLN Driller's well number 2
1/4 Section 30 T. 65 R. 10W W.M.
Tax Lot # _____ Lot _____ Blk _____ Subdivision _____

Address at well location: SAME

(11) WATER LEVEL: Completed well.

Depth at which water was first found 19 ft.
Static level 9 ft. below land surface. Date _____
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 300 ft. Depth of completed well 120 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	1	
BROWN CLAY	1	7	
YELLOW CLAY	7	10	
GRAVEL & SAND	10	34	
GREY CLAYSTONE	34	39	
BROWN CLAYSTONE	39	70	
GREY CLAYSTONE	70	123	
BROWN CLAYSTONE	123	140	
GREY CLAYSTONE	140	163	
BROWN CLAYSTONE	163	181	
GREY CLAYSTONE	181	230	
BROWN CLAYSTONE	230	238	
GREY CLAYSTONE	238	285	
GREY SANDSTONE	285	300	

SALT FOUND AT 290'
CEMENT OFF UP TO 120'
pumped in conductor
(grout)

Work started 8-17 1983 Completed 8-25 1983
Date well drilling machine moved off of well 8-26 1983

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Paul Dickerson Date 8-25 1983
(Drilling Machine Operator)

Drilling Machine Operator's License No. 549

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name DICKERSON WELL DRILLING
(Person, firm or corporation) (Type or print)
Address 1405 ORCHARD Knob Rd., DALLAS, OR.

[Signed] Paul E. Dickerson
(Water Well Contractor)

Contractor's License No. 689 Date 8-25 1983